

# Energy performance certificate (EPC)

FLAT 16  
ST JAMES GATE  
105 PALMERSTON ROAD  
BUCKHURST HILL  
IG9 5NJ

Energy rating

C

Valid until 2 April 2031

Certificate number

3114-0169-8002-0427-9206

## Property type

Mid-floor flat

## Total floor area

58 square metres

## Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

## Energy efficiency rating for this property

This property's current energy rating is C. It has the potential to be C.

[See how to improve this property's energy performance.](#)

| Score | Energy rating | Current | Potential |
|-------|---------------|---------|-----------|
| 92+   | A             |         |           |
| 81-91 | B             |         |           |
| 69-80 | C             | 78   c  | 79   c    |
| 55-68 | D             |         |           |
| 39-54 | E             |         |           |
| 21-38 | F             |         |           |
| 1-20  | G             |         |           |

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

The average energy rating and score for a property in England and Wales are D (60).

### Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

| Feature              | Description                                | Rating  |
|----------------------|--------------------------------------------|---------|
| Wall                 | Cavity wall, as built, insulated (assumed) | Good    |
| Window               | Fully double glazed                        | Average |
| Main heating         | Electric storage heaters                   | Average |
| Main heating control | Automatic charge control                   | Average |
| Hot water            | Electric immersion, off-peak               | Average |

| Feature           | Description                                 | Rating  |
|-------------------|---------------------------------------------|---------|
| Lighting          | Low energy lighting in 40% of fixed outlets | Average |
| Roof              | (another dwelling above)                    | N/A     |
| Floor             | (another dwelling below)                    | N/A     |
| Secondary heating | Room heaters, electric                      | N/A     |

## Primary energy use

The primary energy use for this property per year is 224 kilowatt hours per square metre (kWh/m<sup>2</sup>).

▶ [What is primary energy use?](#)

### Environmental impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO<sub>2</sub>). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO<sub>2</sub> emissions.

### An average household produces

6 tonnes of CO<sub>2</sub>

### This property produces

2.2 tonnes of CO<sub>2</sub>

### This property's potential production

2.1 tonnes of CO<sub>2</sub>

By making the [recommended changes](#), you could reduce this property's CO<sub>2</sub> emissions by 0.1 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

## How to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from C (78) to C (79).

► [What is an energy rating?](#)



## Recommendation 1: Low energy lighting

Low energy lighting

### Typical installation cost

£30

### Typical yearly saving

£27

### Potential rating after carrying out recommendation 1

79 | C

## Paying for energy improvements

[Find energy grants and ways to save energy in your home. \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency)

### Estimated energy use and potential savings

### Estimated yearly energy cost for this property

£497

### Potential saving

£27

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice \(https://www.simpleenergyadvice.org.uk/\)](https://www.simpleenergyadvice.org.uk/).

## Heating use in this property

Heating a property usually makes up the majority of energy costs.

### Estimated energy used to heat this property

### Space heating

1994 kWh per year

---

**Water heating**1773 kWh per year

---

**Potential energy savings by installing insulation**

The assessor did not find any opportunities to save energy by installing insulation in this property.

You might be able to receive [Renewable Heat Incentive payments \(https://www.gov.uk/domestic-renewable-heat-incentive\)](https://www.gov.uk/domestic-renewable-heat-incentive). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

**Contacting the assessor and accreditation scheme**

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

**Assessor contact details****Assessor's name**Ian Willson

---

**Telephone**01245 445215

---

**Email**[ianwillson@hotmail.co.uk](mailto:ianwillson@hotmail.co.uk)

---

**Accreditation scheme contact details****Accreditation scheme**Quidos Limited

---

**Assessor ID**QUID201513

---

**Telephone**01225 667 570

---

**Email**

[info@quidos.co.uk](mailto:info@quidos.co.uk)

---

## Assessment details

### Assessor's declaration

No related party

---

### Date of assessment

29 March 2021

---

### Date of certificate

3 April 2021

---

### Type of assessment

▶ [RdSAP](#)

---

### Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [mhclg.digital-services@communities.gov.uk](mailto:mhclg.digital-services@communities.gov.uk), or call our helpdesk on 020 3829 0748.

### Certificate number

[8899-6627-5500-3784-9992 \(/energy-certificate/8899-6627-5500-3784-9992\)](/energy-certificate/8899-6627-5500-3784-9992)

### Valid until

**14 March 2021 (Expired)**

---

### Certificate number

[0953-2870-6520-0691-9985 \(/energy-certificate/0953-2870-6520-0691-9985\)](/energy-certificate/0953-2870-6520-0691-9985)

### Valid until

**9 February 2019 (Expired)**

---