

# Energy performance certificate (EPC)

5, Stonards Hill  
LOUGHTON  
IG10 3EH

Energy rating

D

Valid until

26 October 2026

Certificate number

9449-2883-7607-9126-7001

Property type

Semi-detached house

Total floor area

82 square metres

## Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read [guidance for landlords on regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## Energy efficiency rating for this property

This property's current energy rating is D. It has the potential to be B.

[See how to improve this property's energy performance.](#)

Score	Energy rating	Current	Potential
92+	<b>A</b>		
81-91	<b>B</b>		82   <b>B</b>
69-80	<b>C</b>		
55-68	<b>D</b>	55   <b>D</b>	
39-54	<b>E</b>		
21-38	<b>F</b>		
1-20	<b>G</b>		

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

### Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says “assumed”, it means that the feature could not be inspected and an assumption has been made based on the property’s age and type.

Feature	Description	Rating
Walls	Solid brick, as built, no insulation (assumed)	Very poor
Walls	Solid brick, as built, insulated (assumed)	Good
Roof	Pitched, 100 mm loft insulation	Average
Floor	Flat, insulated (assumed)	Average
Windows	Partial double glazing	Average
Central heating	Boiler and radiators, mains gas	Good
Central heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in 5% of fixed outlets	Very poor
Basement	Suspended, no insulation (assumed)	N/A
Basement	Suspended, limited insulation (assumed)	N/A
Secondary heating	Room heaters, electric	N/A

## Primary energy use

The primary energy use for this property per year is 301 kilowatt hours per square metre (kWh/m<sup>2</sup>).

[What is primary energy use?](#)

## Environmental impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO<sub>2</sub>). The energy used for heating, lighting and power in homes produces over a quarter of the UK’s CO<sub>2</sub> emissions.

For an average household	6 tonnes of CO <sub>2</sub>
This property produces	4.3 tonnes of CO <sub>2</sub>
This property’s potential reduction	1.5 tonnes of CO <sub>2</sub>

making the [recommended changes](#), you could reduce this property's CO2 emissions by 2.8 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

**How to improve this property's energy performance**

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and move it from D (55) to B (82).

[What is an energy rating?](#)

**Recommendation 1: Internal or external wall insulation**

Internal or external wall insulation

**Typical installation cost**

£4,000 - £14,000

**Typical yearly saving**

£285

**Potential rating after carrying out recommendation 1**

67 | D

**Recommendation 2: Floor insulation (suspended floor)**

Floor insulation (suspended floor)

**Typical installation cost**

£800 - £1,200

**Typical yearly saving**

£46

**Potential rating after carrying out recommendations 1 and 2**

68 | D

**Recommendation 3: Low energy lighting**

Low energy lighting

**Typical installation cost**

£90

**Typical yearly saving**

£43

## Potential rating after carrying out recommendations 1 to 3

70 | C

## Recommendation 4: Solar water heating

Solar water heating

Typical installation cost

£4,000 - £6,000

Typical yearly saving

£36

## Potential rating after carrying out recommendations 1 to 4

71 | C

## Recommendation 5: Solar photovoltaic panels, 2.5 kWp

Solar photovoltaic panels

Typical installation cost

£5,000 - £8,000

Typical yearly saving

£281

## Potential rating after carrying out recommendations 1 to 5

82 | B

## Looking for energy improvements

[Find energy grants and ways to save energy in your home. \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency)

Estimated energy use and potential savings

Estimated yearly energy cost for this property

£1056

Potential saving

£410

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice \(https://www.simpleenergyadvice.org.uk/\)](https://www.simpleenergyadvice.org.uk/).

## Heating use in this property

Heating a property usually makes up the majority of energy costs.

### Estimated energy used to heat this property

Space heating	12460 kWh per year
Water heating	2127 kWh per year

### Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
Loft insulation	335 kWh per year
Solid wall insulation	4951 kWh per year

You might be able to receive [Renewable Heat Incentive payments \(https://www.gov.uk/domestic-renewable-heat-incentive\)](https://www.gov.uk/domestic-renewable-heat-incentive). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

### Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

## Assessor contact details

Assessor's name	Ian Willson
Telephone	01245 445215
Email	<a href="mailto:ianwillson@hotmail.co.uk">ianwillson@hotmail.co.uk</a>

## Accreditation scheme contact details

Accreditation scheme	Quidos Limited
Assessor ID	QUID201513
Telephone	01225 667 570
Email	<a href="mailto:info@quidos.co.uk">info@quidos.co.uk</a>

## Assessment details

Assessor's declaration	No related party
Date of assessment	27 October 2016
Date of certificate	27 October 2016
Type of assessment	► <a href="#">RdSAP</a>

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [ecdg.digital-services@communities.gov.uk](mailto:ecdg.digital-services@communities.gov.uk) or call our helpdesk on 020 3829 0748.

There are no related certificates for this property.