

# Energy performance certificate (EPC)

7, Meadow Road  
LOUGHTON  
IG10 4HY

Energy rating

E

Valid until 9 June 2024

Certificate number

9508-8095-6286-6334-5990

Property type

Semi-detached house

Total floor area

78 square metres

## Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read [guidance for landlords on regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## Energy efficiency rating for this property

This property's current energy rating is E. It has the potential to be B.

[See how to improve this property's energy performance.](#)

Score	Energy rating	Current	Potential
92+	<b>A</b>		
81-91	<b>B</b>		85   <b>B</b>
69-80	<b>C</b>		
55-68	<b>D</b>		
39-54	<b>E</b>	44   <b>E</b>	
21-38	<b>F</b>		
1-20	<b>G</b>		

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

The average energy rating and score for a property in England and Wales are D (60).

## Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Walls	Solid brick, as built, no insulation (assumed)	Very poor
Roof	Pitched, no insulation	Very poor
Floors	Pitched, no insulation (assumed)	Very poor
Windows	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Room thermostat only	Poor
Hot water	From main system	Good
Lighting	No low energy lighting	Very poor
Ground floor	Suspended, no insulation (assumed)	N/A
Basement	Solid, no insulation (assumed)	N/A
Secondary heating	None	N/A

## Primary energy use

The primary energy use for this property per year is 379 kilowatt hours per square metre (kWh/m2).

[What is primary energy use?](#)

## Environmental impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO2). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO2 emissions.

For an average household	6 tonnes of CO2
This property produces	5.7 tonnes of CO2
This property's potential reduction	1.3 tonnes of CO2

By making the [recommended changes](#), you could reduce this property's CO2 emissions by 4.4 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.



## How to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from E (44) to B (85).

[What is an energy rating?](#)



### Recommendation 1: Increase loft insulation to 270 mm

Increase loft insulation to 270 mm

Typical installation cost

£100 - £350

Typical yearly saving

£109.55

Potential rating after carrying out recommendation 1

49 | E

### Recommendation 2: Internal or external wall insulation

Internal or external wall insulation

Typical installation cost

£4,000 - £14,000

Typical yearly saving

£325.81

Potential rating after carrying out recommendations 1 and 2

63 | D

### Recommendation 3: Floor insulation

Under floor insulation

Typical installation cost

£800 - £1,200

Typical yearly saving

£61.17

## Potential rating after carrying out recommendations 1 to 3

66 | D

## Recommendation 4: Low energy lighting

Low energy lighting

Typical installation cost

£70

Typical yearly saving

£39.73

## Potential rating after carrying out recommendations 1 to 4

68 | D

## Recommendation 5: Heating controls (programmer and TRVs)

Heating controls (programmer and TRVs)

Typical installation cost

£350 - £450

Typical yearly saving

£26.31

## Potential rating after carrying out recommendations 1 to 5

69 | C

## Recommendation 6: Replace boiler with new condensing boiler

Condensing boiler

Typical installation cost

£2,200 - £3,000

Typical yearly saving

£88.56

## Potential rating after carrying out recommendations 1 to 6

73 | C

## Recommendation 7: Solar water heating

lar water heating

Typical installation cost	£4,000 - £6,000
---------------------------	-----------------

Typical yearly saving	£28.09
-----------------------	--------

Potential rating after carrying out  
recommendations 1 to 7

74 | C

## Recommendation 8: Solar photovoltaic panels, 2.5 kWp

lar photovoltaic panels

Typical installation cost	£9,000 - £14,000
---------------------------	------------------

Typical yearly saving	£252.73
-----------------------	---------

Potential rating after carrying out  
recommendations 1 to 8

85 | B

## aying for energy improvements

[Find energy grants and ways to save energy in your home. \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency)

Estimated energy use and potential savings

Estimated yearly energy cost for this property	£1252
---	-------

Potential saving	£679
------------------	------

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice \(https://www.simpleenergyadvice.org.uk/\)](https://www.simpleenergyadvice.org.uk/).

## heating use in this property

heating a property usually makes up the majority of energy costs.

## Estimated energy used to heat this property

Space heating	17384 kWh per year
---------------	--------------------

Water heating	2092 kWh per year
---------------	-------------------

## Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
--------------------	------------------------

Loft insulation	2854 kWh per year
-----------------	-------------------

Solid wall insulation	6548 kWh per year
-----------------------	-------------------

You might be able to receive [Renewable Heat Incentive payments \(https://www.gov.uk/domestic-renewable-heat-incentive\)](https://www.gov.uk/domestic-renewable-heat-incentive). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

## Assessor contact details

Assessor's name	Ali Raza
-----------------	----------

Telephone	08001072750
-----------	-------------

Email	<a href="mailto:greendeal@britishgas.co.uk">greendeal@britishgas.co.uk</a>
-------	--

## Accreditation scheme contact details

Accreditation scheme	Stroma Certification Ltd
----------------------	--------------------------

Assessor ID	STRO018755
-------------	------------



---

**Telephone**0330 124 9660

---

**Email**[certification@stroma.com](mailto:certification@stroma.com)

---

## Assessment details

**Assessor's declaration**No related party

---

**Date of assessment**10 June 2014

---

**Date of certificate**10 June 2014

---

**Type of assessment** [RdSAP](#)

---

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [mhclg.digital-services@communities.gov.uk](mailto:mhclg.digital-services@communities.gov.uk), or call our helpdesk on 020 3829 0748.

**Certificate number**[0288-8095-6282-6837-5990 \(/energy-certificate/0288-8095-6282-6837-5990\)](#)**Valid until**9 February 2023

---

**Certificate number**[8981-6526-6980-9398-5096 \(/energy-certificate/8981-6526-6980-9398-5096\)](#)**Valid until****17 June 2019 (Expired)**

---