

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure.

Company / Installer

Engineer Robert Davies
 Company Heat Quick Direct
 Address 5/11 Westbourne Grove
 Studio Three & Four
 London
 Post Code W2 4UA
 Tel No. 0203 697 1259
 Gas Safe Reg 557517
 ID Card No. 557517

Job Address

Name
 Address 80
 Jeddo Road
 London
 Post Code W12 9EQ
 Tel. No

Customer / Landlord

Name Ms Jasmine Alaoui
 Company Cow & Co
 Address 1 Lower Ground Floor
 10 Barley Mow Passage
 Chiswick
 London
 Post Code W4 4PH
 Tel. No 02080650010

Appliance Details
Inspection Details

No	Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
										Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Out House	Boiler	Valliant	Eco Tec Plus	NA	Yes	Yes	20	24	NA	0.009	NA	NA	0.007	NA	Yes	Yes	Yes	Pass	No	Yes
2	Landing	Hob	Neff	Unknown	OF	Yes	Yes	6	5	NA	NA	NA	NA	NA	Yes	Yes	Yes	Pass	No	Yes	
3																					
4																					
5																					
6																					

Defects / Identified

Labels and Warning Notice Issued

CO Alarm(s)
Smoke Alarm(s)

1		NA		
2		NA		
3				
4				
5				
6				

CO Alarm(s) fitted	Yes	Smoke Alarm(s) fitted	Yes
CO Alarm(s) tested and Satisfactory	Pass	Smoke Alarm(s) tested and Satisfactory	Pass

 Emergency Control Accessible Yes Gas Tightness Satisfactory Yes

 Gas Installation Pipework Visual Inspection Satisfactory Yes

 Equipotential Bonding Yes

NEXT INSPECTION DUE ON OR BEFORE 22-Feb-2022
Comments**Signatures**

Issued by: Signed
 Print Name Robert Davies

Received Signed by:
 Print Name

 Date 22-Feb-2021