

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure.

Company / Installer

Engineer Robert Davies
 Company Heat Quick Direct
 Address 5/11 Westbourne Grove
 Studio Three & Four
 London
 Post Code W2 4UA
 Tel No. 0203 697 1259
 Gas Safe Reg 557517
 ID Card No. 557517

Job Address

Name
 Address 32
 Leythe Road
 London
 Post Code W3 8AW
 Tel. No

Customer / Landlord

Name Ms Jasmine Alaoui
 Company Cow & Co
 Address 1 Lower Ground Floor
 10 Barley Mow Passage
 Chiswick
 London
 Post Code W4 4PH
 Tel. No 02080650010

Appliance Details
Inspection Details

	Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
										Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Kitchen	Boiler	Valliant	Combination	RS	Yes	Yes	19	24	NA	0.006	NA	NA	0.006	NA	Yes	Yes	Yes	Pass	No	Yes
2	Kitchen	Hob	Bosch	Unknown	OF	Yes	Yes	5	4	NA	NA	NA	NA	NA	Yes	Yes	Yes	Pass	No	Yes	
3																					
4																					
5																					
6																					

Defects / Identified

Labels and Warning Notice Issued

CO Alarm(s)
Smoke Alarm(s)

1		NA			
2		NA			
3					
4					
5					
6					

CO Alarm(s) fitted Yes

CO Alarm(s) tested and Satisfactory Pass

Smoke Alarm(s) fitted Yes

Smoke Alarm(s) tested and Satisfactory Pass

 Emergency Control Accessible Yes Gas Tightness Satisfactory Yes

 Gas Installation Pipework Visual Inspection Satisfactory Yes

 Equipotential Bonding Yes

NEXT INSPECTION DUE ON OR BEFORE 23-Feb-2022
Comments**Signatures**

Issued by: Signed
 Print Name Robert Davies

Received Signed by:
 Print Name

 Date 23-Feb-2021