

# Home Report

**Thorntons**  
The right way to move




03330 430090

[thorntons-property.co.uk](https://thorntons-property.co.uk)



# Home Report

[shepherd.co.uk](https://shepherd.co.uk)



## **SHEPHERD**

**CHARTERED SURVEYORS**

All Angles Covered

Residential | Commercial | Property & Construction



## Contents

---

1. Scottish Single Survey
  2. Energy Performance Certificate
  3. Property Questionnaire
-





# Scottish Single Survey



# Single Survey

survey report on:

|                    |                                               |
|--------------------|-----------------------------------------------|
| Property address   | 49 Silverknowes Grove<br>Edinburgh<br>EH4 5NH |
| Customer           | David Treherne Exy                            |
| Customer address   | 49 Silverknowes Grove<br>Edinburgh<br>EH4 5NH |
| Prepared by        | Shepherd Chartered Surveyors                  |
| Date of inspection | 18/11/2024                                    |



[www.shepherd.co.uk](http://www.shepherd.co.uk)

## PART 1 - GENERAL

### 1.1 THE SURVEYORS

The Seller has engaged the Surveyors to provide the Single Survey Report and a generic Mortgage Valuation Report for Lending Purposes. The Seller has also engaged the Surveyors to provide an Energy Report in the format prescribed by the accredited Energy Company.

The Surveyors are authorised to provide a transcript or retype of the generic Mortgage Valuation Report on to Lender specific pro-forma. Transcript reports are commonly requested by Brokers and Lenders. The transcript report will be in the format required by the Lender but will contain the same information, inspection date and valuation figure as the generic Mortgage Valuation Report and the Single Survey. The Surveyors will decline any transcript request which requires the provision of information additional to the information in the Report and the generic Mortgage Valuation Report until the Seller has conditionally accepted an offer to purchase made in writing.

Once the Seller has conditionally accepted an offer to purchase made in writing, the Purchaser's lender or conveyancer may request that the Surveyors provide general comment on standard appropriate supplementary documentation. In the event of a significant amount of documentation being provided to the Surveyors, an additional fee may be incurred by the Purchaser. Any additional fee will be agreed in writing.

If information is provided to the Surveyors during the conveyancing process which materially affects the valuation stated in the Report and generic Mortgage Valuation Report, the Surveyors reserve the right to reconsider the valuation. Where the Surveyors require to amend the valuation in consequence of such information, they will issue an amended Report and generic Mortgage Valuation Report to the Seller. It is the responsibility of the Seller to ensure that the amended Report and generic Mortgage Valuation Report are transmitted to every prospective Purchaser.

The individual Surveyor will be a member of the Royal Institution of Chartered Surveyors who is competent to survey, value and report upon Residential Property<sup>1</sup>.

If the Surveyors have had a previous business relationship within the past two years with the Seller or Seller's Agent or relative to the property, they will be obliged to indicate this by marking the adjacent box.

☐

The Surveyors have a written complaints handling procedure. This is available from the offices of the Surveyors at the address stated.

### 1.2 THE REPORT

The Surveyors will not provide an amended Report on the Property, except to correct factual inaccuracies.

The Report will identify the nature and source of information relied upon in its preparation.

The Surveyor shall provide a Market Value of the Property, unless the condition of the Property is such that it would be inappropriate to do so. A final decision on whether a loan will be granted rests with the Lender who may impose retentions in line with their lending criteria. The date of condition and value of the property will be the date of inspection.

Prior to 1 December 2008, Purchasers have normally obtained their own report from their chosen Surveyor. By contrast, a Single Survey is instructed by the Seller and made available to all potential Purchasers in expectation that the successful Purchaser will have relied upon it. The Royal Institution of Chartered Surveyors rules require disclosure of any potential conflict of interest when acting for the Seller and the Purchaser in the same transaction. The Single Survey may give rise to a conflict of interest and if this is of concern to any party they are advised to seek their own independent advice.

The Report and any expressions or assessments in it are not intended as advice to the Seller or Purchaser or any other person in relation to an asking price or any other sales or marketing decisions.

---

<sup>1</sup> Which shall be in accordance with the current RICS Valuation Standards (The Red Book) and RICS Rules of Conduct.

The Report is based solely on the Property and is not to be relied upon in any manner whatsoever when considering the valuation or condition of any other property.

If certain minor matters are mentioned in the Report it should not be assumed that the Property is free of other minor defects.

Neither the whole nor any part of the Report may be published in any way, reproduced or distributed by any party other than the Seller, prospective purchasers and the Purchaser and their respective professional advisers without the prior written consent of the Surveyors.

## 1.3 LIABILITY

The Report is prepared with the skill and care reasonably to be expected of a competent residential surveyor who is a member of the Royal Institution of Chartered Surveyors.

The Report is addressed to the Seller and was prepared in the expectation that it (or a complete copy) along with these Terms and Conditions (or a complete copy) would (or, as the case might be, would have been) be disclosed and delivered to:

- the Seller;
- any person(s) noting an interest in purchasing the Property from the Seller;
- any person(s) who make(s) (or on whose behalf is made) an offer to purchase the Property, whether or not that offer is accepted by the Seller;
- the Purchaser; and
- the professional advisers of any of these.

The Surveyors acknowledge that their duty of skill and care in relation to the Report is owed to the Seller and to the Purchaser. The Surveyors accept no responsibility or liability whatsoever in relation to the Report to persons other than the Seller and the Purchaser. The Seller and Purchaser should be aware that if a Lender seeks to rely on this Report they do so at their own risk. In particular, the Surveyors accept no responsibility or liability whatsoever to any Lender in relation to the Report. Any such Lender relies upon the Report entirely at their own risk.

## 1.4 GENERIC MORTGAGE VALUATION REPORT

The Surveyors undertake to the Seller that they will prepare a generic Mortgage Valuation Report, which will be issued along with the Single Survey. It is the responsibility of the Seller to ensure that the generic Mortgage Valuation Report is provided to every potential Purchaser.

## 1.5 TRANSCRIPT MORTGAGE VALUATION FOR LENDING PURPOSES

The Surveyors undertake that on being asked to do so by a prospective purchaser, or his/her professional advisor or Lender, they will prepare a Transcript Mortgage Valuation Report for Lending Purposes on terms and conditions to be agreed between the Surveyors and Lender and solely for the use of the Lender and upon which the Lender may rely. The decision as to whether finance will be provided is entirely a matter for the Lender. The Transcript Mortgage Valuation Report will be prepared from information contained in the Report and the generic Mortgage Valuation Report<sup>2</sup>.

## 1.6 INTELLECTUAL PROPERTY

All intellectual property rights whatsoever (including copyright) in and to the Report, excluding the headings and rubrics, are the exclusive property of the Surveyors and shall remain their exclusive property unless

---

<sup>2</sup> Which shall be in accordance with the current RICS Valuation Standards (The Red Book) and RICS Rules of Conduct.

they assign the same to any other party in writing.

## 1.7 PAYMENT

The Surveyors are entitled to refrain from delivering the Report to anyone until the fee and other charges for it notified to the Seller have been paid. Additional fees will be charged for subsequent inspections and Reports.

## 1.8 CANCELLATION

The Seller will be entitled to cancel the inspection by notifying the Surveyor's office at any time before the day of the inspection.

The Surveyor will be entitled not to proceed with the inspection (and will so report promptly to the Seller) if after arriving at the property, the Surveyor concludes that it is of a type of construction of which the Surveyor has insufficient specialist knowledge to be able to provide the inspection satisfactorily. The Surveyor will also be entitled not to proceed if after arriving at the property, the surveyor concludes that the property is exempt under Part 3 of The Housing (Scotland) Act 2006 as detailed in the (Prescribed Documents) Regulations 2008. If there is a potential threat to their health or personal safety, the inspection may be postponed or cancelled, at the Surveyor's discretion.

In the case of cancellation or the inspection not proceeding, the Surveyor will refund any fees paid by the Seller for the inspection and Report, except for expenses reasonably incurred and any fee due in light of the final paragraph of this section.

In the case of cancellation by the Seller, for whatever reason, after the inspection has taken place but before a written report is issued, the Surveyor will be entitled to raise an invoice equivalent to 80% of the agreed fee.

## 1.9 PRECEDENCE

If there is any incompatibility between these Terms and Conditions and the Report, these Terms and Conditions take precedence.

## 1.10 DEFINITIONS

- the "Lender" is the party who has provided or intends or proposes to provide financial assistance to the Purchaser towards the purchase of the Property and in whose favour a standard security will be granted over the Property;
- the "Transcript Mortgage Valuation Report for Lending Purposes" means a separate report, prepared by the Surveyor, prepared from information in the Report and the generic Mortgage Valuation Report, but in a style and format required by the Lender. The Transcript Mortgage Valuation Report for Lending Purposes will be prepared with the skill and care reasonably to be expected from a surveyor who is a member of the Royal Institution of Chartered Surveyors and who is competent to survey, value and report on the Property;
- the "Generic Mortgage Valuation Report" means a separate report, prepared by the Surveyor from information in the Report but in the Surveyor's own format;
- the "Market Value" is the estimated amount for which a property should exchange on the date of valuation between a willing buyer and a willing seller in an arm's-length transaction after proper marketing wherein the parties had each acted knowledgeably, prudently and without compulsion;
- the "Property" is the property which forms the subject of the Report;
- the "Purchaser" is the person (or persons) who enters into a contract to buy the Property from the Seller;



- a "prospective Purchaser" is anyone considering buying the Property;
- the "Report" is the report, of the kind described in Part 2 of these Terms and Conditions and in the form set out in part 1 of Schedule 1 of the Housing (Scotland) Act 2006 (Prescribed Documents) Regulations 2008;
- the "Seller" is/are the proprietor(s) of the Property;
- the "Surveyor" is the author of the Report on the Property; and
- the "Surveyors" are the firm or company of which the Surveyor is an employee, director, member or partner (unless the Surveyor is not an employee, director, member or partner, when the "Surveyors" means the Surveyor) whose details are set out at the head of the Report.
- the "Energy Report" is the advice given by the accredited Energy Company, based on information collected by the Surveyor during the Inspection, and also includes an Energy Performance Certificate, in a Government approved format.

## PART 2 - DESCRIPTION OF THE REPORT

### 2.1 THE SERVICE

The Single Survey is a Report by an independent Surveyor, prepared in an objective way regarding the condition and value of the Property on the day of the inspection, and who is a member of the Royal Institution of Chartered Surveyors. It includes an Energy Report as required by Statute and this is in the format of the accredited Energy Company. In addition, the Surveyor has agreed to supply a generic Mortgage Valuation Report.

### 2.2 THE INSPECTION

The Inspection is a general surface examination of those parts of the Property which are accessible: in other words, *visible and readily available for examination from ground and floor levels, without risk of causing damage to the Property or injury to the Surveyor.*

All references to visual inspection refer to an inspection from within the property at floor level and from ground level within the site and adjoining public areas, without the need to move any obstructions. Any references to left or right are taken facing the front of the property.

The Inspection is carried out with the Seller's permission, without causing damage to the building or contents. Furniture, stored items and insulation are not moved.

Unless identified in the report the Surveyor will assume that no harmful or hazardous materials have been used in the construction. The presence or possible consequences of any site contamination will not be researched.

The Surveyor will not carry out an asbestos inspection, and will not be acting as an asbestos inspector in completing a Single Survey of properties that may fall within the Control of Asbestos in the Workplace Regulations. In the case of flats it will be assumed that there is a duty holder, as defined in the Regulations and that a Register of Asbestos and effective Management Plan is in place, which does not require any expenditure, or pose a significant risk to health. No enquiry of the duty holder will be made.

### 2.3 THE REPORT

The Report will be prepared by the Surveyor who carried out the property inspection and will describe various aspects of the property as defined by the headings of the Single Survey report with the comments

being general and unbiased. The report on the location, style and condition of the property, will be concise and will be restricted to matters that could have a material effect upon value and will omit items that, in the Surveyor's opinion, are not significant. If certain minor matters are mentioned, it should not be interpreted that the property is free of any other minor defects.

Throughout the Report, the following repair categories will be used to give an overall opinion of the state of repair and condition of the property.

- 1 Category 3: Urgent repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.
- 2 Category 2: Repairs or replacement requiring future attention, but estimates are still advised.
- 3 Category 1: No immediate action or repair is needed.

**WARNING:** If left unattended, even for a relatively short period, Category 2 repairs can rapidly develop into more serious Category 3 repairs. The existence of Category 2 or Category 3 repairs may have an adverse effect on marketability, value and the sale price ultimately achieved for the property. This is particularly true during slow market conditions when the effect can be considerable.

Parts of the property, which cannot be seen or accessed, will not be reported upon and this will be stated. If the Surveyor suspects that a defect may exist within an unexposed area and which could have a material effect upon the value, he may recommend further investigation by specialist contractors.

## 2.4 SERVICES

Surveyors are not equipped or qualified to test the services and therefore no comment can be interpreted as implying that the design, installation and function of the services are in accordance/compliance with regulations, safety and efficiency expectations. However, comment is made where there is cause to suspect significant defects or shortcomings with the installations. No tests are made of any services or appliances.

## 2.5 ACCESSIBILITY

A section is included to help identify the basic information interested parties need to know to decide whether to view a property.

## 2.6 ENERGY REPORT

A section is included that makes provision for an Energy Report, relative to the property. The Surveyor will collect physical data from the property and provide such data in a format required by an accredited Energy Company. The Surveyor cannot of course accept liability for any advice given by the Energy Company.

## 2.7 VALUATION AND CONVEYANCER ISSUES

The last section of the Report contains matters considered relevant to the Conveyancer (Solicitor). It also contains the Surveyor's opinion both of the market value of the property and of the re-instatement cost, as defined below.

*"Market Value" The estimated amount for which a property should exchange on the date of valuation between a willing buyer and a willing seller in an arm's-length transaction after proper marketing wherein the parties had each acted knowledgeably, prudently and without compulsion.* In arriving at the opinion of the Market Value the Surveyor also makes various standard assumptions covering, for example, vacant possession; tenure and other legal considerations; contamination and hazardous materials; the condition of un-inspected parts; the right to use mains services; and the exclusion of curtains, carpets etc. from the valuation. In the case of flats, the following further assumptions are made that:

- There are rights of access and exit over all communal roadways, corridors, stairways etc. and to use

# Terms and Conditions

communal grounds, parking areas, and other facilities;

- There are no particularly troublesome or unusual legal restrictions;
- There is no current dispute between the occupiers of the flats or any outstanding claims or losses; and the costs of repairs to the building are shared among the co-proprietors on an equitable basis.

Any additional assumption, or any found not to apply, is reported.

"Re-instatement cost" *is an estimate for insurance purposes of the current cost of rebuilding the Property in its present form* unless otherwise stated. This includes the cost of rebuilding the garage and permanent outbuildings, site clearance and professional fees, but excludes VAT (except on the fees).

Sellers or prospective Purchasers may consider it prudent to instruct a reinspection and revaluation after a period of 12 weeks (or sooner if appropriate) to reflect changing circumstances in the market and/or in the physical condition of the Property.

## 1. Information and scope of inspection

This section tells you about the type, accommodation, neighbourhood, age and construction of the property. It also tells you about the extent of the inspection and highlights anything that the surveyor could not inspect.

All references to visual inspection refer to an inspection from within the property without moving any obstructions and externally from ground level within the site and adjoining public areas. Any references to left or right in a description of the exterior of the property refer to the view of someone standing facing that part of the property from the outside.

The inspection is carried out without causing damage to the building or its contents and without endangering the occupiers or the surveyor. Heavy furniture, stored items and insulation are not moved. Unless identified in the report the surveyor will assume that no harmful or hazardous materials or techniques have been used in the construction. The presence or possible consequences of any site contamination will not be researched.

Services such as TV/cable connection, internet connection, swimming pools and other leisure facilities etc. will not be inspected or reported on.

|                                                  |                                                                                                                                                                                                                     |
|--------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Description</b>                               | Detached house.                                                                                                                                                                                                     |
| <b>Accommodation</b>                             | Ground Floor: Entrance hall, living room, kitchen, garden room and wc compartment.<br><br>First Floor: Landing, three bedrooms and play room accessed via the front and rear bedrooms, wet room and wc compartment. |
| <b>Gross internal floor area (m<sup>2</sup>)</b> | 120m2 or thereby.                                                                                                                                                                                                   |
| <b>Neighbourhood and location</b>                | The subjects are situated within an established residential area where neighbouring properties are of a similar age and type. Adequate amenities can be found nearby.                                               |
| <b>Age</b>                                       | 1957 or thereby.                                                                                                                                                                                                    |
| <b>Weather</b>                                   | Dry and clear.                                                                                                                                                                                                      |
| <b>Chimney stacks</b>                            | <b>Visually inspected with the aid of binoculars where appropriate.</b><br><br>Masonry with clay pots.                                                                                                              |

|                                     |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
|-------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Roofing including roof space        | <p>Sloping roofs were visually inspected with the aid of binoculars where appropriate.</p> <p>Flat roofs were visually inspected from vantage points within the property and where safe and reasonable to do so from a 3m ladder externally.</p> <p>Roof spaces were visually inspected and were entered where there was safe and reasonable access, normally defined as being from a 3m ladder within the property.</p> <p>If this is not possible, then physical access to the roof space may be taken by other means if the Surveyor deems it safe and reasonable to do so.</p> <p>The roof is pitched and laid in tile incorporating flat roof sections. Access to the roof void is afforded via a hatch at top floor landing. At the time of inspection the roof void area was floored and lined. A restricted inspection was carried out to around the hatch only due to health and safety restrictions.</p> |
| Rainwater fittings                  | <p>Visually inspected with the aid of binoculars where appropriate.</p> <p>Cast iron gutters and downpipes.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
| Main walls                          | <p>Visually inspected with the aid of binoculars where appropriate.</p> <p>Foundations and concealed parts were not exposed or inspected.</p> <p>The main walls are of masonry construction rendered externally.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
| Windows, external doors and joinery | <p>Internal and external doors were opened and closed where keys were available.</p> <p>Random windows were opened and closed where possible.</p> <p>Doors and windows were not forced open.</p> <p>The windows throughout are of replacement UPVC double glazed type. There is front and rear access doors.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| External decorations                | <p>Visually inspected.</p> <p>Painted finishes noted.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |



# Single Survey

|                                       |                                                                                                                                                                                                                                                                                                                                      |
|---------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Conservatories / porches              | <b>Visually inspected.</b><br><br>Not applicable.                                                                                                                                                                                                                                                                                    |
| Communal areas                        | <b>Circulation areas visually inspected.</b><br><br>Not applicable.                                                                                                                                                                                                                                                                  |
| Garages and permanent outbuildings    | <b>Visually inspected.</b><br><br>The property benefits from an attached single car garage.                                                                                                                                                                                                                                          |
| Outside areas and boundaries          | <b>Visually inspected.</b><br><br>There is a driveway to the front of the property with garden grounds to the front and rear bounded by a mixture of boundaries.                                                                                                                                                                     |
| Ceilings                              | <b>Visually inspected from floor level.</b><br><br>Presumed plastered ceilings throughout.                                                                                                                                                                                                                                           |
| Internal walls                        | <b>Visually inspected from floor level.</b><br><br><b>Using a moisture meter, walls were randomly tested for dampness where considered appropriate.</b><br><br>Plaster finishing.                                                                                                                                                    |
| Floors including sub floors           | <b>Surfaces of exposed floors were visually inspected. No carpets or floor coverings were lifted.</b><br><br>The flooring throughout appears to be of timber construction with fitted floor coverings. No sub floor access was gained at the time of inspection.                                                                     |
| Internal joinery and kitchen fittings | <b>Built-in cupboards were looked into but no stored items were moved.</b><br><br><b>Kitchen units were visually inspected excluding appliances.</b><br><br>Internal Joinery - Timber.<br><br>Internal Doors - Timber panel type.<br><br>Kitchen storage is provided by a range of fitted units incorporating worktop surface areas. |

## Single Survey


|                                    |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
|------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Chimney breasts and fireplaces     | <p><b>Visually inspected.</b></p> <p><b>No testing of the flues or fittings was carried out.</b></p> <p>There is a gas fire within the living room.</p>                                                                                                                                                                                                                                                                                                                           |
| Internal decorations               | <p><b>Visually inspected.</b></p> <p>Painted, papered and tile finishes noted.</p>                                                                                                                                                                                                                                                                                                                                                                                                |
| Cellars                            | <p><b>Visually inspected where there was a safe and purpose-built access.</b></p> <p>None noted at the time of inspection.</p>                                                                                                                                                                                                                                                                                                                                                    |
| Electricity                        | <p><b>Accessible parts of the wiring were visually inspected without removing fittings. No tests whatsoever were carried out to the system or appliances. Visual inspection does not assess any services to make sure they work properly and efficiently and meet modern standards. If any services are turned off, the surveyor will state that in the report and will not turn them on.</b></p> <p>Mains supply. The electric meter is located in the under stair cupboard.</p> |
| Gas                                | <p><b>Accessible parts of the system were visually inspected without removing fittings. No tests whatsoever were carried out to the system or appliances. Visual inspection does not assess any services to make sure they work properly and efficiently and meet modern standards. If any services are turned off, the surveyor will state that in the report and will not turn them on.</b></p> <p>Mains supply.</p>                                                            |
| Water, plumbing, bathroom fittings | <p><b>Visual inspection of the accessible pipework, water tanks, cylinders and fittings without removing any insulation.</b></p> <p><b>No tests whatsoever were carried out to the system or appliances.</b></p> <p>Mains supply. There is a sink unit within the kitchen.</p> <p>Sanitary Arrangements:-</p> <p>Wet room and separate wc compartment. There is a further wc compartment at ground floor level.</p>                                                               |

## Single Survey

|                                |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
|--------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Heating and hot water          | <p><b>Visual inspection of the accessible pipework, water tanks, cylinders and fittings without removing any insulation.</b></p> <p><b>No tests whatsoever were carried out to the system or appliances.</b></p> <p>The property benefits from electric room heaters. There is a gas wall heater within the hallway. There is no central heating system with the property. Domestic hot water is provided via the hot water cylinder.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| Drainage                       | <p><b>Drainage covers etc. were not lifted.</b></p> <p><b>Neither drains nor drainage systems were tested.</b></p> <p>Presumed to main public sewer.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| Fire, smoke and burglar alarms | <p><b>Visually inspected.</b></p> <p><b>No tests whatsoever were carried out to the system or appliances.</b></p> <p>All Scottish homes require a smoke alarm to be installed in the room most frequently used for living purposes and in every circulation space on each floor. A heat alarm also needs to be installed in each kitchen. The alarms need to be ceiling mounted and interlinked. Where there is a carbon-fuelled appliance such as a boiler, open fire or wood burner, a carbon monoxide detector is also required. We have not assessed or tested any existing equipment and it is the purchasers responsibility to confirm that the property will comply with these standards following a change of ownership.</p> <p>It was advised by the vendor that the smoke alarms are interlinked and this should be confirmed and checked prior to purchase.</p> |

|                                            |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |
|--------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Any additional limits to inspection</b> | <p><b>For flats / maisonettes</b></p> <p><b>Only the subject flat and internal communal areas giving access to the flat were inspected.</b></p> <p><b>If the roof space or under-building / basement is communal, reasonable and safe access is not always possible. If no inspection was possible, this will be stated. If no inspection was possible, the surveyor will assume that there are no defects that will have a material effect on the valuation.</b></p> <p><b>The building containing the flat, including any external communal areas, was visually inspected only to the extent that the surveyor is able to give an opinion on the general condition and standard of maintenance.</b></p> <p>At the time of inspection the some floors were covered. A restricted inspection was carried out to the roof void area due to the presence of flooring and lining. A restricted inspection due to health and safety restrictions was undertaken from around the hatch only. No sub floor access was gained at the time of inspection. No access was gained below or beyond the sanitary arrangements. Windows and doors were tested at random. Roof decks and chimneys were viewed predominately from ground floor level. At the time of inspection there was a light frost covering over the roof coverings.</p> <p>This report should not be construed as a detailed and intrusive structural survey.</p> <p>Properties built prior to 1999 may contain elements of asbestos materials however an asbestos survey has not been carried out.</p> <p>An inspection for Japanese Knotweed was not carried out. This is a plant which is subject to control regulation, is considered to be invasive and one which can render a property unsuitable for some mortgage lenders. It is therefore assumed that there is no Japanese Knotweed within the boundaries of the property or its neighbouring property. Identification of Japanese Knotweed is best undertaken by a specialist contractor.</p> |
|--------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

## Sectional Diagram showing elements of a typical house



Reference may be made in this report to some or all of the above component parts of the property. This diagram may assist you in locating and understanding these items.

# Single Survey

## 2. Condition

This section identifies problems and tells you about the urgency of any repairs by using one of the following three categories:

| Category 3                                                                                                                                                                                               | Category 2                                                                          | Category 1                               |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|------------------------------------------|
| Urgent repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now. | Repairs or replacement requiring future attention, but estimates are still advised. | No immediate action or repair is needed. |



### Structural movement

|                 |                                           |
|-----------------|-------------------------------------------|
| Repair category | 1                                         |
| Notes           | No obvious or significant movement noted. |



### Dampness, rot and infestation

|                 |                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
|-----------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| Notes           | <p>Elevated condensation meter readings were recorded at lower ground walls in the property and around the coombed areas at first floor level. We recommend vacant properties are well vented to alleviate any moisture build up.</p> <p>A restricted damp inspection was carried out due to the presence of linings and fittings. No comment can be made to the condition of the fabric below any floor coverings or behind any wall linings.</p> |



### Chimney stacks

|                 |                                                                                                                                                                                                                                                                                                                                                                                                                          |
|-----------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Notes           | <p>Weathered masonry was noted. A precautionary check of the surrounding flashings should be carried out by a qualified Roofing Contractor prior to purchase to ensure complete water tightness.</p> <p>Our inspection of chimneys was limited but they are of an age and style where a degree of regular ongoing maintenance should be anticipated.</p> <p>Chimney stacks were viewed from ground floor level only.</p> |





## Roofing including roof space

|                 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
|-----------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
| Notes           | <p>Flat roof coverings have a limited life and will require regular and ongoing maintenance. At the time of inspection the flat roof sections of the rear of the property were covered over via a light frost covering. Damaged masonry was noted to the gable end. The roof coverings appear original and will require regular and ongoing maintenance works.</p> <p>A precautionary check of the roof decks and pertinents is recommended by a qualified Roofing Contractor prior to purchase. Roofing Contractors can provide advice on any necessary remedial works required prior to purchase.</p> <p>Stained sarking boards were noted in the roof void area. Where tested in sections these areas were dry, however, all sections of the roof void could not be tested and as such a precautionary check of this area is recommended by a qualified Roofing Contractor prior to purchase.</p> <p>Roof decks were viewed predominately from ground floor level.</p> |



## Rainwater fittings

|                 |                                                                                                                                                                                                                                                                                                                                     |
|-----------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                                                                                                                                                                                                                   |
| Notes           | <p>Sections of the rainwater fittings were noted to be weathered and corroded. Remedial works are required.</p> <p>We would highlight that it was not raining at the time of our inspection and we would recommend that all rainwater fittings be inspected during heavy rainfall in order to ensure they are free from defect.</p> |



## Main walls

|                 |                                                                                                                                                  |
|-----------------|--------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                                |
| Notes           | <p>Weathered masonry was noted. Ongoing maintenance work should be anticipated and carried out in accordance with good maintenance practice.</p> |



## Windows, external doors and joinery

|                 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
|-----------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| Notes           | <p>The top floor window unit is cracked and will require to be replaced. Failed double glazing was noted within the rear extension. Remedial works are required. A number of window units are dated and may be approaching the end of their working life cycle. Upgrading with modern equivalent should be anticipated.</p> <p>It is assumed that replacement windows and doors comply with relevant building and fire regulations.</p> <p>A precautionary check of all windows and doors is always recommended by a qualified glazing contractor prior to purchase who can provide advice and recommendations on any necessary remedial works.</p> |



## External decorations

|                 |                                                                                              |
|-----------------|----------------------------------------------------------------------------------------------|
| Repair category | 1                                                                                            |
| Notes           | Paint finished and decorated external surfaces will require redecoration on a regular basis. |



## Conservatories/porches

|                 |                 |
|-----------------|-----------------|
| Repair category | N/A             |
| Notes           | Not applicable. |



## Communal areas

|                 |                 |
|-----------------|-----------------|
| Repair category | N/A             |
| Notes           | Not applicable. |



## Garages and permanent outbuildings

|                 |                                                                                                                                                                                                                                                                                                                                                     |
|-----------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                                                                                                                                                                                                                                   |
| Notes           | <p>Weathered and damaged masonry noted to sections of lower ground walls within the garage. The lintel above the rear window is cracked. The concrete paneling within the garage is weathered. Exposed wiring was noted in the garage. Remedial works are required and checks should be undertaken via qualified contractors prior to purchase.</p> |

# Single Survey



## Outside areas and boundaries

|                 |                                                                                                                                                          |
|-----------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 1                                                                                                                                                        |
| Notes           | Boundary walls and fences should be regularly checked and maintained as necessary. The garden was covered in a frost covering at the time of inspection. |



## Ceilings

|                 |                                                                                                                                    |
|-----------------|------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                  |
| Notes           | Stained and cracked plaster work was noted. Remedial works are required and cosmetic upgrading should be budgeted for accordingly. |



## Internal walls

|                 |                                                                                                                                    |
|-----------------|------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                  |
| Notes           | Stained and cracked plaster work was noted. Remedial works are required and cosmetic upgrading should be budgeted for accordingly. |



## Floors including sub-floors

|                 |                                                                                                                                                                                                                                                                                                                                |
|-----------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 1                                                                                                                                                                                                                                                                                                                              |
| Notes           | <p>Due to fitted carpets and floor coverings no detailed inspection of floors was possible and accordingly no comment can be made on their condition.</p> <p>Uneven and creaky flooring was noted. No comment can be made to the condition of the fabric below any fitted floor coverings. No sub floor access was gained.</p> |



## Internal joinery and kitchen fittings

|                 |                                                                                                                                                                                                                                              |
|-----------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                                                                                                                            |
| Notes           | <p>The kitchen units would benefit from being upgraded with a modern equivalent.</p> <p>Internal joinery is generally serviceable however some wear and tear items were noted and future maintenance or upgrading should be anticipated.</p> |



## Chimney breasts and fireplaces

|                 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
|-----------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| Notes           | <p>The gas fire within the living room is dated and would benefit from being upgraded with a modern equivalent.</p> <p>It is assumed that the gas fire has been installed in accordance with the manufacturer's recommendations for fluing and ventilation and that this has been regularly checked and tested. All test documentation should be obtained and authenticated at the point of sale. In the absence of any such documentation, the appliance should be tested by a registered engineer prior to use.</p> |



## Internal decorations

|                 |                                                                                                                                                                                                                                                                                                              |
|-----------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                                                                                                                                                                                            |
| Notes           | <p>The internal decoration will require to be upgraded dependant on individual taste. Polystyrene tiles should be upgraded as they pose a fire hazard. An asbestos survey has not been carried out to categorically confirm/deny the presence of any asbestos materials within any decorative coverings.</p> |



## Cellars

|                 |                 |
|-----------------|-----------------|
| Repair category | N/A             |
| Notes           | Not applicable. |



## Electricity

|                 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |
|-----------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
| Notes           | <p>The electrical system is dated and would benefit from being upgraded with a modern equivalent. We recommend a precautionary check of the electrical system is advised by a qualified Electrician prior to purchase. A qualified Electrician can provide an up to date EICR Report which can provide recommendations on any necessary works required to the electrical system to ensure the system is in line with current regulations.</p> <p>The Institution of Engineering Technology recommends that inspections and testings are undertaken at least every five years and on a change of occupancy. It should be appreciated that only the most recently constructed or re-wired properties will have installations which fully comply with IET regulations.</p> <p>Only recently re-wired properties will fully comply with current regulations, as such aspects of the electrical system could be dated in line with current regulations. We recommend a qualified electrician carry out an inspection of the system prior to purchase.</p> |



## Gas

|                 |                                                                                                                                                           |
|-----------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 1                                                                                                                                                         |
| Notes           | In the interests of safety and in light of recent regulations it would be prudent to have all gas appliances checked by a Gas Safe registered contractor. |



## Water, plumbing and bathroom fittings

|                 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
|-----------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 1                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| Notes           | <p>Properties of this age and type may contain elements of concealed lead plumbing. Where this is the case we recommend any lead plumbing is upgraded with a modern equivalent.</p> <p>There is a redundant galvanised cold water tank within the roof void area. It is presumed this will be suitably disconnected by a qualified contractor. A precautionary check of the plumbing lines and system should be undertaken prior to purchase via a qualified plumber.</p> <p>We presume the sealants around the sanitary fittings are functional and no defects are present to the adjacent areas. A precautionary check of the areas below and adjacent to the sanitary fittings is always recommended prior to purchase as these areas are prone to leakage.</p> |



## Heating and hot water

|                 |                                                                                                                                                                                                                                                                     |
|-----------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 2                                                                                                                                                                                                                                                                   |
| Notes           | The property does not benefit from a central heating system. The subjects should be upgraded to incorporate a fully functioning central heating system. A precautionary check of the hot water cylinder is recommended by a qualified contractor prior to purchase. |



## Drainage

|                 |                                                                                                                                                                                                                                                                                                      |
|-----------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Repair category | 1                                                                                                                                                                                                                                                                                                    |
| Notes           | <p>All foul and surface water drainage is assumed to be to the main public sewer. The system was not tested.</p> <p>Properties of this age and type may contain elements of concealed lead plumbing. Where this is the case we recommend any lead plumbing is upgraded with a modern equivalent.</p> |

# Single Survey

Set out below is a summary of the condition of the property which is provided for reference only. You should refer to the previous comments for detailed information.

|                                       |     |
|---------------------------------------|-----|
| Structural movement                   | 1   |
| Dampness, rot and infestation         | 2   |
| Chimney stacks                        | 2   |
| Roofing including roof space          | 2   |
| Rainwater fittings                    | 2   |
| Main walls                            | 2   |
| Windows, external doors and joinery   | 2   |
| External decorations                  | 1   |
| Conservatories/porches                | N/A |
| Communal areas                        | N/A |
| Garages and permanent outbuildings    | 2   |
| Outside areas and boundaries          | 1   |
| Ceilings                              | 2   |
| Internal walls                        | 2   |
| Floors including sub-floors           | 1   |
| Internal joinery and kitchen fittings | 2   |
| Chimney breasts and fireplaces        | 2   |
| Internal decorations                  | 2   |
| Cellars                               | N/A |
| Electricity                           | 2   |
| Gas                                   | 1   |
| Water, plumbing and bathroom fittings | 1   |
| Heating and hot water                 | 2   |
| Drainage                              | 1   |

## Category 3

Urgent repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.

## Category 2

Repairs or replacement requiring future attention, but estimates are still advised.

## Category 1

No immediate action or repair is needed.

### Remember

The cost of repairs may influence the amount someone is prepared to pay for the property. We recommend that relevant estimates and reports are obtained in your own name.

### Warning

If left unattended, even for a relatively short period, Category 2 repairs can rapidly develop into more serious Category 3 repairs. The existence of Category 2 or Category 3 repairs may have an adverse effect on marketability, value and the sale price ultimately achieved for the property. This is particularly true during slow market conditions where the effect can be considerable.



## 3. Accessibility information

### Guidance notes on accessibility information

*Three steps or fewer to a main entrance door of the property:*

In flatted developments the 'main entrance' would be the flat's own entrance door, not the external door to the communal stair. The 'three steps or fewer' are counted from external ground level to the flat's entrance door. Where a lift is present, the count is based on the number of steps climbed when using the lift.

*Unrestricted parking within 25 metres:*

For this purpose, 'Unrestricted parking' includes parking available by means of a parking permit. Restricted parking includes parking that is subject to parking restrictions, as indicated by the presence of solid yellow, red or white lines at the edge of the road or by a parking control sign, parking meters or other coin-operated machines.

| 1. Which floor(s) is the living accommodation on?                                      | Ground and First |                                     |    |                                     |
|----------------------------------------------------------------------------------------|------------------|-------------------------------------|----|-------------------------------------|
| 2. Are there three steps or fewer to a main entrance door of the property?             | Yes              | <input checked="" type="checkbox"/> | No | <input type="checkbox"/>            |
| 3. Is there a lift to the main entrance door of the property?                          | Yes              | <input type="checkbox"/>            | No | <input checked="" type="checkbox"/> |
| 4. Are all door openings greater than 750mm?                                           | Yes              | <input type="checkbox"/>            | No | <input checked="" type="checkbox"/> |
| 5. Is there a toilet on the same level as the living room and kitchen?                 | Yes              | <input checked="" type="checkbox"/> | No | <input type="checkbox"/>            |
| 6. Is there a toilet on the same level as a bedroom?                                   | Yes              | <input checked="" type="checkbox"/> | No | <input type="checkbox"/>            |
| 7. Are all rooms on the same level with no internal steps or stairs?                   | Yes              | <input type="checkbox"/>            | No | <input checked="" type="checkbox"/> |
| 8. Is there unrestricted parking within 25 metres of an entrance door to the building? | Yes              | <input checked="" type="checkbox"/> | No | <input type="checkbox"/>            |

## 4. Valuation and conveyancer issues

This section highlights information that should be checked with a solicitor or licensed conveyancer. It also gives an opinion of market value and an estimated reinstatement cost for insurance purposes.

### Matters for a solicitor or licensed conveyancer

An extension has been erected to the rear elevation. The extension itself is not compliant in that the walls are only 100mm thick and therefore not considered suitable security for mortgage purposes. This has been taken into account within our valuation.

It appears the property has been altered to form its current internal layout. It is presumed any documentation has been obtained for other works.

Rights of access, land ownership and maintenance liabilities around the periphery of the subjects should be confirmed with an inspection of the Title Deeds.

Where areas of maintenance, defects or repairs have been identified within this report it is recommended that, prior to entering into any legally binding sale or purchase contract, further specialist's or contractor's advice and estimates should be obtained, to establish the implications, if any, on a potential offer to purchase or the sale price likely to be achieved for the property.

It is assumed that there are no statutory, town planning, road proposals or environmental matters which are likely to have an adverse effect on the property.

The road and footpath adjoining the site are made up and are assumed to be adopted by the Local Authority.

### Estimated reinstatement cost for insurance purposes

For Reinstatement Cost Assessment purposes, it is recommended that the subjects be insured for a sum of not less than £400,000 (Four Hundred Thousand Pounds Sterling).

This figure is the estimate of the cost of rebuilding the premises and bears no direct relationship to current market value.

### Valuation and market comments

Having considered matters, taking account of our general observations on site, we are of the opinion that the Market Value of the subjects in their present condition and with the benefit of vacant possession may be fairly stated in the sum of £420,000 (Four Hundred and Twenty Thousand Pounds Sterling).

**Signed**

*Graeme Haywood*  
Electronically signed :- 21/11/2024 17:38

# Single Survey

|                       |                                            |
|-----------------------|--------------------------------------------|
| <b>Report author</b>  | Graeme Haywood                             |
| <b>Company name</b>   | J & E Shepherd Chartered Surveyors         |
| <b>Address</b>        | 12 Atholl Crescent<br>Edinburgh<br>EH3 8HA |
| <b>Date of report</b> | 18/11/2024                                 |

# Mortgage Valuation Report



www.shepherd.co.uk

## Property Address

Address 49 Silverknowes Grove, Edinburgh, EH4 5NH  
Seller's Name David Treherne Exy  
Date of Inspection 18/11/2024

## Property Details

Property Type ☒ House ☐ Bungalow ☐ Purpose built maisonette ☐ Converted maisonette  
☐ Purpose built flat ☐ Converted flat ☐ Tenement flat ☐ Flat over non-residential use  
☐ Other (specify in General Remarks)

Property Style ☒ Detached ☐ Semi detached ☐ Mid terrace ☐ End terrace  
☐ Back to back ☐ High rise block ☐ Low rise block ☐ Other (specify in General Remarks)

Does the surveyor believe that the property was built for the public sector, e. g. local authority, military, police? ☐ Yes ☒ No

Flats/Maisonettes only Floor(s) on which located  No. of floors in block  Lift provided? ☐ Yes ☐ No  
No. of units in block

Approximate Year of Construction

## Tenure

☒ Absolute Ownership ☐ Other

## Accommodation

Number of Rooms  Living room(s)  Bedroom(s)  Kitchen(s)  
 Bathroom(s)  WC(s)  Other (Specify in General remarks)

Gross Floor Area (excluding garages and outbuildings)  m<sup>2</sup> (Internal)  m<sup>2</sup> (External)  
Residential Element (greater than 40%) ☒ Yes ☐ No

## Garage / Parking / Outbuildings

☒ Single garage ☐ Double garage ☐ Parking space ☐ No garage / garage space / parking space

Available on site? ☒ Yes ☐ No

Permanent outbuildings:

None.

# Mortgage Valuation Report

## Construction

Walls ☒ Brick ☐ Stone ☐ Concrete ☐ Timber frame ☐ Other (specify in General Remarks)  
Roof ☐ Tile ☐ Slate ☐ Asphalt ☐ Felt ☒ Other (specify in General Remarks)

## Special Risks

Has the property suffered structural movement? ☐ Yes ☒ No

If Yes, is this recent or progressive? ☐ Yes ☐ No

Is there evidence, history, or reason to anticipate subsidence, heave, landslip or flood in the immediate vicinity? ☐ Yes ☒ No

If Yes to any of the above, provide details in General Remarks.

## Service Connections

Based on visual inspection only. If any services appear to be non-mains, please comment on the type and location of the supply in General Remarks

Drainage ☒ Mains ☐ Private ☐ None Water ☒ Mains ☐ Private ☐ None  
Electricity ☒ Mains ☐ Private ☐ None Gas ☐ Mains ☐ Private ☒ None  
Central Heating ☐ Yes ☒ Partial ☐ None

Brief description of Central Heating and any non mains services:

Electric room heaters are present alongside a wall mounted gas heater within the hall.

## Site

Apparent legal issues to be verified by the conveyancer. Please provide a brief description in General Remarks.

☐ Rights of way ☐ Shared drives / access ☐ Garage or other amenities on separate site ☐ Shared service connections  
☐ Ill-defined boundaries ☐ Agricultural land included with property ☐ Other (specify in General Remarks)

## Location

☐ Residential suburb ☒ Residential within town / city ☐ Mixed residential / commercial ☐ Shared service connections  
☐ Commuter village ☐ Remote village ☐ Isolated rural property ☐ Other (specify in General Remarks)

## Planning Issues

Has the property been extended / converted / altered? ☒ Yes ☐ No

If Yes provide details in General Remarks.

## Roads

☒ Made up road ☐ Unmade road ☐ Partly completed new road ☐ Pedestrian access only ☐ Adopted ☐ Unadopted

# Mortgage Valuation Report

## General Remarks

At the time of inspection the property appeared in a condition and future upgrading work should be anticipated to the both the internal and external fabric.

Flat roof coverings have a limited life and will require regular and ongoing maintenance with higher than average maintenance costs.

Due to the age and style of construction ongoing maintenance and upgrading work should be anticipated to the external fabric, in particular to the chimneys, roof, rainwater fittings, main walls, site boundaries and garage. This should be carried out in accordance with good practice.

The electrical system is dated and would benefit from being upgraded with a modern equivalent.

An extension has been erected to the rear elevation. The extension itself is not compliant in that the walls are only 100mm thick and therefore not considered suitable security for mortgage purposes. This has been taken into account within our valuation.

It appears the property has been altered to form its current internal layout. It is presumed any documentation has been obtained for other works.

Rights of access, land ownership and maintenance liabilities around the periphery of the subjects should be confirmed with an inspection of the Title Deeds.

Where areas of maintenance, defects or repairs have been identified within this report it is recommended that, prior to entering into any legally binding sale or purchase contract, further specialist's or contractor's advice and estimates should be obtained, to establish the implications, if any, on a potential offer to purchase or the sale price likely to be achieved for the property.

It is assumed that there are no statutory, town planning, road proposals or environmental matters which are likely to have an adverse effect on the property.

The road and footpath adjoining the site are made up and are assumed to be adopted by the Local Authority.

## Essential Repairs

None.

Estimated cost of essential repairs

Retention recommended? ☐ Yes ☒ No

Retention amount

## Comment on Mortgageability

The property forms suitable security for mortgage purposes subject to the specific lending criteria of any mortgage provider.



# Mortgage Valuation Report

## Valuation

|                                                                                                          |                              |                                        |
|----------------------------------------------------------------------------------------------------------|------------------------------|----------------------------------------|
| Market value in present condition                                                                        | £                            | <input type="text" value="420,000"/>   |
| Market value on completion of essential repairs                                                          | £                            | <input type="text"/>                   |
| Insurance reinstatement value                                                                            | £                            | <input type="text" value="400,000"/>   |
| (to include the cost of total rebuilding, site clearance, professional fees, ancillary charges plus VAT) |                              |                                        |
| Is a reinspection necessary?                                                                             | <input type="checkbox"/> Yes | <input checked="" type="checkbox"/> No |

## Declaration

|                             |                                                                    |
|-----------------------------|--------------------------------------------------------------------|
| Signed                      | <i>Graeme Haywood</i><br>Electronically signed :- 21/11/2024 17:38 |
| Surveyor's name             | Graeme Haywood                                                     |
| Professional qualifications | MA (Hons), MRICS                                                   |
| Company name                | J & E Shepherd Chartered Surveyors                                 |
| Address                     | 12 Atholl Crescent, Edinburgh, EH3 8HA                             |
| Telephone                   | 0131 225 1234                                                      |
| Email Address               | edinburghadminresi@shepherd.co.uk                                  |
| Date of Inspection          | 18/11/2024                                                         |



# Energy Performance Certificate



# Energy Performance Certificate (EPC)

# Scotland

Dwellings

49 SILVERKNOWES GROVE, SILVERKNOWES, EDINBURGH, EH4 5NH

**Dwelling type:** Detached house  
**Date of assessment:** 18 November 2024  
**Date of certificate:** 21 November 2024  
**Total floor area:** 122 m<sup>2</sup>  
**Primary Energy Indicator:** 560 kWh/m<sup>2</sup>/year


**Reference number:** 9384-1919-6209-5114-0204  
**Type of assessment:** RdSAP, existing dwelling  
**Approved Organisation:** Elmhurst  
**Main heating and fuel:** Room heaters, electric

## You can use this document to:

- Compare current ratings of properties to see which are more energy efficient and environmentally friendly
- Find out how to save energy and money and also reduce CO<sub>2</sub> emissions by improving your home

|                                                   |         |                                                      |
|---------------------------------------------------|---------|------------------------------------------------------|
| Estimated energy costs for your home for 3 years* | £15,690 | See your recommendations report for more information |
| Over 3 years you could save*                      | £11,580 |                                                      |

\* based upon the cost of energy for heating, hot water, lighting and ventilation, calculated using standard assumptions




## Energy Efficiency Rating

This graph shows the current efficiency of your home, taking into account both energy efficiency and fuel costs. The higher this rating, the lower your fuel bills are likely to be.

Your current rating is **band F (23)**. The average rating for EPCs in Scotland is **band D (61)**.

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.



## Environmental Impact (CO<sub>2</sub>) Rating

This graph shows the effect of your home on the environment in terms of carbon dioxide (CO<sub>2</sub>) emissions. The higher the rating, the less impact it has on the environment.

Your current rating is **band F (27)**. The average rating for EPCs in Scotland is **band D (59)**.

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.

## Top actions you can take to save money and make your home more efficient

| Recommended measures                 | Indicative cost | Typical savings over 3 years |
|--------------------------------------|-----------------|------------------------------|
| 1 Cavity wall insulation             | £500 - £1,500   | £2277.00                     |
| 2 Floor insulation (suspended floor) | £800 - £1,200   | £1617.00                     |
| 3 Gas condensing boiler              | £3,000 - £7,000 | £7320.00                     |

A full list of recommended improvement measures for your home, together with more information on potential cost and savings and advice to help you carry out improvements can be found in your recommendations report.

To find out more about the recommended measures and other actions you could take today to stop wasting energy and money, visit [greenerscotland.org](https://www.greenerscotland.org) or contact Home Energy Scotland on 0808 808 2282.

**THIS PAGE IS THE ENERGY PERFORMANCE CERTIFICATE WHICH MUST BE AFFIXED TO THE DWELLING AND NOT BE REMOVED UNLESS IT IS REPLACED WITH AN UPDATED CERTIFICATE**

## Summary of the energy performance related features of this home

This table sets out the results of the survey which lists the current energy-related features of this home. Each element is assessed by the national calculation methodology; 1 star = very poor (least efficient), 2 stars = poor, 3 stars = average, 4 stars = good and 5 stars = very good (most efficient). The assessment does not take into consideration the condition of an element and how well it is working. 'Assumed' means that the insulation could not be inspected and an assumption has been made in the methodology, based on age and type of construction.

| Element               | Description                                         | Energy Efficiency | Environmental |
|-----------------------|-----------------------------------------------------|-------------------|---------------|
| Walls                 | Cavity wall, as built, no insulation (assumed)      | ★★☆☆☆             | ★★☆☆☆         |
|                       | Cavity wall, as built, partial insulation (assumed) | ★★★☆☆             | ★★★☆☆         |
| Roof                  | Pitched, 200 mm loft insulation                     | ★★★★☆             | ★★★★☆         |
|                       | Flat, limited insulation (assumed)                  | ★★☆☆☆             | ★★☆☆☆         |
| Floor                 | Suspended, no insulation (assumed)                  | —                 | —             |
|                       | To unheated space, no insulation (assumed)          | —                 | —             |
| Windows               | Fully double glazed                                 | ★★★★☆             | ★★★★☆         |
| Main heating          | Room heaters, electric                              | ★★☆☆☆             | ★★☆☆☆         |
| Main heating controls | Appliance thermostats                               | ★★★★☆             | ★★★★☆         |
| Secondary heating     | None                                                | —                 | —             |
| Hot water             | Electric immersion, off-peak                        | ★★☆☆☆             | ★★☆☆☆         |
| Lighting              | Low energy lighting in 67% of fixed outlets         | ★★★★☆             | ★★★★☆         |

## The energy efficiency rating of your home

Your Energy Efficiency Rating is calculated using the standard UK methodology, RdSAP. This calculates energy used for heating, hot water, lighting and ventilation and then applies fuel costs to that energy use to give an overall rating for your home. The rating is given on a scale of 1 to 100. Other than the cost of fuel for electrical appliances and for cooking, a building with a rating of 100 would cost almost nothing to run.

As we all use our homes in different ways, the energy rating is calculated using standard occupancy assumptions which may be different from the way you use it. The rating also uses national weather information to allow comparison between buildings in different parts of Scotland. However, to make information more relevant to your home, local weather data is used to calculate your energy use, CO<sub>2</sub> emissions, running costs and the savings possible from making improvements.

## The impact of your home on the environment

One of the biggest contributors to global warming is carbon dioxide. The energy we use for heating, lighting and power in our homes produces over a quarter of the UK's carbon dioxide emissions. Different fuels produce different amounts of carbon dioxide for every kilowatt hour (kWh) of energy used. The Environmental Impact Rating of your home is calculated by applying these 'carbon factors' for the fuels you use to your overall energy use.

The calculated emissions for your home are 95 kg CO<sub>2</sub>/m<sup>2</sup>/yr.

The average Scottish household produces about 6 tonnes of carbon dioxide every year. Based on this assessment, heating and lighting this home currently produces approximately 12 tonnes of carbon dioxide every year. Adopting recommendations in this report can reduce emissions and protect the environment. If you were to install all of these recommendations this could reduce emissions by 8.7 tonnes per year. You could reduce emissions even more by switching to renewable energy sources.





## Estimated energy costs for this home

|               | Current energy costs | Potential energy costs | Potential future savings                                                            |
|---------------|----------------------|------------------------|-------------------------------------------------------------------------------------|
| Heating       | £13,818 over 3 years | £3,228 over 3 years    |  |
| Hot water     | £1,338 over 3 years  | £351 over 3 years      |                                                                                     |
| Lighting      | £534 over 3 years    | £531 over 3 years      |                                                                                     |
| <b>Totals</b> | <b>£15,690</b>       | <b>£4,110</b>          |                                                                                     |

These figures show how much the average household would spend in this property for heating, lighting and hot water. This excludes energy use for running appliances such as TVs, computers and cookers, and the benefits of any electricity generated by this home (for example, from photovoltaic panels). The potential savings in energy costs show the effect of undertaking all of the recommended measures listed below.

## Recommendations for improvement

The measures below will improve the energy and environmental performance of this dwelling. The performance ratings after improvements listed below are cumulative; that is, they assume the improvements have been installed in the order that they appear in the table. Further information about the recommended measures and other simple actions to take today to save money is available from the Home Energy Scotland hotline which can be contacted on 0808 808 2282. Before carrying out work, make sure that the appropriate permissions are obtained, where necessary. This may include permission from a landlord (if you are a tenant) or the need to get a Building Warrant for certain types of work.

| Recommended measures                      | Indicative cost | Typical saving per year | Rating after improvement                                                              |                                                                                       |
|-------------------------------------------|-----------------|-------------------------|---------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------|
|                                           |                 |                         | Energy                                                                                | Environment                                                                           |
| 1 Cavity wall insulation                  | £500 - £1,500   | £759                    |  |  |
| 2 Floor insulation (suspended floor)      | £800 - £1,200   | £539                    |  |  |
| 3 Change heating to gas condensing boiler | £3,000 - £7,000 | £2440                   |  |  |
| 4 Solar water heating                     | £4,000 - £6,000 | £58                     |  |  |
| 5 Replacement glazing units               | £1,000 - £1,400 | £63                     |  |  |
| 6 Solar photovoltaic panels, 2.5 kWp      | £3,500 - £5,500 | £455                    |  |  |

### Alternative measures

There are alternative improvement measures which you could also consider for your home. It would be advisable to seek further advice and illustration of the benefits and costs of such measures.

- External insulation with cavity wall insulation
- Biomass boiler (Exempted Appliance if in Smoke Control Area)
- Air or ground source heat pump
- Micro CHP

## Choosing the right improvement package

For free and impartial advice on choosing suitable measures for your property, contact the Home Energy Scotland hotline on 0808 808 2282 or go to [www.greenerscotland.org](http://www.greenerscotland.org).

## About the recommended measures to improve your home's performance rating

This section offers additional information and advice on the recommended improvement measures for your home

### 1 Cavity wall insulation

Cavity wall insulation, to fill the gap between the inner and outer layers of external walls with an insulating material, reduces heat loss; this will improve levels of comfort, reduce energy use and lower fuel bills. The insulation material is pumped into the gap through small holes that are drilled into the outer walls, and the holes are made good afterwards. As specialist machinery is used to fill the cavity, a professional installation company should carry out this work, and they should carry out a thorough survey before commencing work to ensure that this type of insulation is suitable for this home and its exposure. They should also provide a guarantee for the work and handle any building standards issues. Further information about cavity wall insulation and details of local installers can be obtained from the National Insulation Association ([www.nationalinsulationassociation.org.uk](http://www.nationalinsulationassociation.org.uk)).

### 2 Floor insulation (suspended floor)

Insulation of a floor will significantly reduce heat loss; this will improve levels of comfort, reduce energy use and lower fuel bills. Suspended floors can often be insulated from below but must have adequate ventilation to prevent dampness; seek advice about this if unsure. Further information about floor insulation is available from many sources including [www.energysavingtrust.org.uk/scotland/Insulation/Floor-insulation](http://www.energysavingtrust.org.uk/scotland/Insulation/Floor-insulation). Building regulations generally apply to this work so it is best to check with your local authority building standards department.

### 3 Gas condensing boiler

Changing the heating to use a mains gas boiler that provides both space and water heating will save money, as mains gas is currently cheaper than the fuel being used at present. A condensing boiler is capable of higher efficiencies than other types of boiler, meaning it will burn less fuel to heat the property, but there may be exceptional circumstances making this impractical. Condensing boilers need a drain for the condensate which limits their location; remember this when considering remodelling the room containing the existing boiler even if the latter is to be retained for the time being (for example a kitchen makeover). This improvement is most appropriate when the existing heating system needs repair or replacement. Building regulations generally apply to this work and a building warrant may be required, so it is best to check with your local authority building standards department and seek advice from a qualified heating engineer.

### 4 Solar water heating

A solar water heating panel, usually fixed to the roof, uses the sun to pre-heat the hot water supply. This can significantly reduce the demand on the heating system to provide hot water and hence save fuel and money. Planning permission might be required, building regulations generally apply to this work and a building warrant may be required, so it is best to check these with your local authority. You could be eligible for Renewable Heat Incentive payments which could appreciably increase the savings beyond those shown on your EPC, provided that both the product and the installer are certified by the Microgeneration Certification Scheme (or equivalent). Details of local MCS installers are available at [www.microgenerationcertification.org](http://www.microgenerationcertification.org).

### 5 Replacement glazing units

Replacing existing double-glazed units with new high-performance units. Building regulations require that replacement glazing is to a standard no worse than previous; a building warrant is not required. Planning permission might be required for such work if a building is listed or within a conservation area so it is best to check with your local authority.

### 6 Solar photovoltaic (PV) panels

A solar PV system is one which converts light directly into electricity via panels placed on the roof with no waste and no emissions. This electricity is used throughout the home in the same way as the electricity purchased from an energy supplier. Planning permission might be required, building regulations generally apply to this work and a building warrant may be required, so it is best to check with your local authority. The assessment does not include the effect of any Feed-in Tariff which could appreciably increase the savings that are shown on this EPC for solar photovoltaic panels, provided that both the product and the installer are certified by the Microgeneration Certification Scheme (or equivalent). Details of local MCS installers are available at [www.microgenerationcertification.org](http://www.microgenerationcertification.org).

## Low and zero carbon energy sources

Low and zero carbon (LZC) energy sources are sources of energy that release either very little or no carbon dioxide into the atmosphere when they are used. Installing these sources may help reduce energy bills as well as cutting carbon.

**LZC energy sources present:** There are none provided for this home

## Your home's heat demand

In this section, you can see how much energy you might need to heat your home and provide hot water. These are estimates showing how an average household uses energy. These estimates may not reflect your actual energy use, which could be higher or lower. You might spend more money on heating and hot water if your house is less energy efficient. The table below shows the potential benefit of having your loft and walls insulated. Visit <https://energysavingtrust.org.uk/energy-at-home> for more information.

| Heat demand                  | Existing dwelling | Impact of loft insulation | Impact of cavity wall insulation | Impact of solid wall insulation |
|------------------------------|-------------------|---------------------------|----------------------------------|---------------------------------|
| Space heating (kWh per year) | 19,350            | N/A                       | (3,188)                          | N/A                             |
| Water heating (kWh per year) | 2,290             |                           |                                  |                                 |

## Addendum

### About this document

This Recommendations Report and the accompanying Energy Performance Certificate are valid for a maximum of ten years. These documents cease to be valid where superseded by a more recent assessment of the same building carried out by a member of an Approved Organisation.

The Energy Performance Certificate and this Recommendations Report for this building were produced following an energy assessment undertaken by an assessor accredited by Elmhurst ([www.elmhurstenergy.co.uk](http://www.elmhurstenergy.co.uk)), an Approved Organisation Appointed by Scottish Ministers. The certificate has been produced under the Energy Performance of Buildings (Scotland) Regulations 2008 from data lodged to the Scottish EPC register. You can verify the validity of this document by visiting [www.scottishepcregister.org.uk](http://www.scottishepcregister.org.uk) and entering the report reference number (RRN) printed at the top of this page.

|                             |                                                                        |
|-----------------------------|------------------------------------------------------------------------|
| Assessor's name:            | Mr. Graeme Haywood                                                     |
| Assessor membership number: | EES/014225                                                             |
| Company name/trading name:  | J & E Shepherd                                                         |
| Address:                    | 12 Atholl Crescent<br>Edinburgh<br>EH3 8HA                             |
| Phone number:               | 0131 225 1234                                                          |
| Email address:              | <a href="mailto:edinburgh@shepherd.co.uk">edinburgh@shepherd.co.uk</a> |
| Related party disclosure:   | No related party                                                       |

If you have any concerns regarding the content of this report or the service provided by your assessor you should in the first instance raise these matters with your assessor and with the Approved Organisation to which they belong. All Approved Organisations are required to publish their complaints and disciplinary procedures and details can be found online at the web address given above.

### Use of this energy performance information

Once lodged by your EPC assessor, this Energy Performance Certificate and Recommendations Report are available to view online at [www.scottishepcregister.org.uk](http://www.scottishepcregister.org.uk), with the facility to search for any single record by entering the property address. This gives everyone access to any current, valid EPC except where a property has a Green Deal Plan, in which case the report reference number (RRN) must first be provided. The energy performance data in these documents, together with other building information gathered during the assessment is held on the Scottish EPC Register and is available to authorised recipients, including organisations delivering energy efficiency and carbon reduction initiatives on behalf of the Scottish and UK governments. A range of data from all assessments undertaken in Scotland is also published periodically by the Scottish Government. Further information on these matters and on Energy Performance Certificates in general, can be found at [www.gov.scot/epc](http://www.gov.scot/epc).



## Advice and support to improve this property

There is support available, which could help you carry out some of the improvements recommended for this property on page 3 and stop wasting energy and money. For more information, visit [greenerscotland.org](https://www.greenerscotland.org) or contact Home Energy Scotland on 0808 808 2282.

Home Energy Scotland's independent and expert advisors can offer free and impartial advice on all aspects of energy efficiency, renewable energy and more.

**HOMEENERGYSCOTLAND.ORG**  
**0808 808 2282**  
FUNDED BY THE SCOTTISH GOVERNMENT





# Property Questionnaire



# property questionnaire

|                                           |                                               |
|-------------------------------------------|-----------------------------------------------|
| Property address                          | 49 Silverknowes Grove<br>Edinburgh<br>EH4 5NH |
| Seller(s)                                 | David Treherne Exy                            |
| Completion date of property questionnaire | 13/11/2024                                    |

# property questionnaire

## Note for sellers

- Please complete this form carefully. It is important that your answers are correct.
- The information in your answers will help ensure that the sale of your house goes smoothly. Please answer each question with as much detailed information as you can.
- If anything changes after you fill in this questionnaire but before the date of entry for the sale of your house, tell your solicitor or estate agent immediately.

## Information to be given to prospective buyer(s)

|    |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                  |
|----|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|
| 1. | Length of ownership                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |                  |
|    | How long have you owned the property?                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       | Parents 58 years |
| 2. | Council tax                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |                  |
|    | Which Council Tax band is your property in?                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | F                |
| 3. | Parking                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                  |
|    | <p>What are the arrangements for parking at your property?<br/>(Please tick all that apply)</p> <ul style="list-style-type: none"><li>• Garage <input type="text" value="Yes"/></li><li>• Allocated parking space <input type="text" value="No"/></li><li>• Driveway <input type="text" value="Yes"/></li><li>• Shared parking <input type="text" value="No"/></li><li>• On street <input type="text" value="No"/></li><li>• Resident permit <input type="text" value="No"/></li><li>• Metered Parking <input type="text" value="No"/></li><li>• Other (please specify):<br/><input type="text"/></li></ul> |                  |
| 4. | Conservation area                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |                  |
|    | Is your property in a designated Conservation Area (that is an area of special architectural or historical interest, the character or appearance of which it is desirable to preserve or enhance)?                                                                                                                                                                                                                                                                                                                                                                                                          | No               |

# property questionnaire

|    |                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |     |
|----|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----|
| 5. | <b>Listed buildings</b>                                                                                                                                                                                                                                                                                                                                                                                                                                            |     |
|    | Is your property a Listed Building, or contained within one (that is a building recognised and approved as being of special architectural or historical interest)?                                                                                                                                                                                                                                                                                                 | No  |
| 6. | <b>Alterations/additions/extensions</b>                                                                                                                                                                                                                                                                                                                                                                                                                            |     |
| a. | <p>(i) During your time in the property, have you carried out any structural alterations, additions or extensions (for example, provision of an extra bath/shower room, toilet, or bedroom)?</p> <p><u>If you have answered yes</u>, please describe below the changes which you have made:</p> <p>Extension to rear, 1 room plus additional toilet</p>                                                                                                            | Yes |
|    | <p>(ii) Did you obtain planning permission, building warrant, completion certificate and other consents for this work?</p> <p><u>If you have answered yes</u>, the relevant documents will be needed by the purchaser and you should give them to your solicitor as soon as possible for checking.</p> <p>If you do not have the documents yourself, please note below who has these documents and your solicitor or estate agent will arrange to obtain them:</p> | Yes |
| b. | <p>Have you had replacement windows, doors, patio doors or double glazing installed in your property?</p> <p><u>If you have answered yes</u>, please answer the three questions below:</p>                                                                                                                                                                                                                                                                         | Yes |
|    | (i) Were the replacements the same shape and type as the ones you replaced?                                                                                                                                                                                                                                                                                                                                                                                        | Yes |
|    | (ii) Did this work involve any changes to the window or door openings?                                                                                                                                                                                                                                                                                                                                                                                             | No  |
|    | <p>(iii) Please describe the changes made to the windows doors, or patio doors (with approximate dates when the work was completed):</p> <p>Please give any guarantees which you received for this work to your solicitor or estate agent.</p> <p>Double glazed 1980<br/>New front door 2018</p>                                                                                                                                                                   |     |
| 7. | <b>Central heating</b>                                                                                                                                                                                                                                                                                                                                                                                                                                             |     |
| a. | <p>Is there a central heating system in your property?<br/>(Note: a partial central heating system is one which does not heat all the main rooms of the property — the main living room, the bedroom(s), the hall and the bathroom).</p> <p><u>If you have answered yes or partial</u> – what kind of central heating is there?</p>                                                                                                                                | No  |

# property questionnaire

|     |                                                                                                                                                                                                              |           |                 |
|-----|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------|-----------------|
|     | (Examples: gas-fired, solid fuel, electric storage heating, gas warm air).                                                                                                                                   |           |                 |
|     | <u>If you have answered yes</u> , please answer the three questions below:                                                                                                                                   |           |                 |
|     | i) When was your central heating system or partial central heating system installed?                                                                                                                         |           |                 |
|     | (ii) Do you have a maintenance contract for the central heating system?<br><u>If you have answered yes</u> , please give details of the company with which you have a maintenance contract:                  |           |                 |
|     | (iii) When was your maintenance agreement last renewed?<br>(Please provide the month and year).                                                                                                              |           |                 |
| 8.  | Energy Performance Certificate                                                                                                                                                                               |           |                 |
|     | Does your property have an Energy Performance Certificate which is less than 10 years old?                                                                                                                   |           | No              |
| 9.  | Issues that may have affected your property                                                                                                                                                                  |           |                 |
| a.  | Has there been any storm, flood, fire or other structural damage to the property while you have owned it?<br><u>If you have answered yes</u> , is the damage the subject of any outstanding insurance claim? |           | No              |
| b.  | Are you aware of the existence of asbestos in your property?<br><u>If you have answered yes</u> , please give details:                                                                                       |           | No              |
| 10. | Services                                                                                                                                                                                                     |           |                 |
| a.  | Please tick which services are connected to your property and give details of the supplier:                                                                                                                  |           |                 |
|     | Services                                                                                                                                                                                                     | Connected | Supplier        |
|     | Gas or liquid petroleum gas                                                                                                                                                                                  | Yes       | Scottish Gas    |
|     | Water mains or private water supply                                                                                                                                                                          | Yes       | Scottish Water  |
|     | Electricity                                                                                                                                                                                                  | Yes       | Scottish Gas    |
|     | Mains drainage                                                                                                                                                                                               | Yes       | Local Authority |
|     | Telephone                                                                                                                                                                                                    | Yes       | BT cancelled    |

# property questionnaire

|     |                                                                                                                                                                                                                 |     |                         |
|-----|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----|-------------------------|
|     | Cable TV or satellite                                                                                                                                                                                           | No  |                         |
|     | Broadband                                                                                                                                                                                                       | Yes | BT full fibre cancelled |
| b.  | Is there a septic tank system at your property?                                                                                                                                                                 |     | No                      |
|     | <u>If you have answered yes</u> , please answer the two questions below:                                                                                                                                        |     |                         |
|     | (i) Do you have appropriate consents for the discharge from your septic tank?                                                                                                                                   |     |                         |
|     | (ii) Do you have a maintenance contract for your septic tank?                                                                                                                                                   |     |                         |
|     | <u>If have answered yes</u> , details of the company with which you have a maintenance contract:                                                                                                                |     |                         |
| 11. | Responsibilities for shared or common areas                                                                                                                                                                     |     |                         |
| a.  | Are you aware of any responsibility to contribute to the cost of anything used jointly, such as the repair of a shared drive, private road, boundary, or garden area?                                           |     | No                      |
|     | <u>If you have answered yes</u> , please give details:                                                                                                                                                          |     |                         |
| b.  | Is there a responsibility to contribute to repair and maintenance of the roof, common stairwell or other common areas?                                                                                          |     | No                      |
|     | <u>If you have answered yes</u> , please give details:                                                                                                                                                          |     |                         |
| c.  | Has there been any major repair or replacement of any part of the roof during the time you have owned the property?                                                                                             |     | No                      |
| d.  | Do you have the right to walk over any of your neighbours' property — for example to put out your rubbish bin or to maintain your boundaries?                                                                   |     | No                      |
|     | <u>If you have answered yes</u> , please give details:                                                                                                                                                          |     |                         |
| e.  | As far as you are aware, do any of your neighbours have the right to walk over your property, for example to put out their rubbish bin or to maintain their boundaries?                                         |     | No                      |
|     | <u>If you have answered yes</u> , please give details:                                                                                                                                                          |     |                         |
| f.  | As far as you are aware, is there a public right of way across any part of your property? (public right of way is a way over which the public has a right to pass, whether or not the land is privately-owned.) |     | No                      |
|     | <u>If you have answered yes</u> , please give details:                                                                                                                                                          |     |                         |



# property questionnaire

|     |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |    |
|-----|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----|
| 12. | Charges associated with the property                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |    |
| a.  | <p>Is there a factor or property manager for your property?</p> <p><u>If you have answered yes</u>, please provide the name and address, and give details of any deposit held and approximate charges:</p>                                                                                                                                                                                                                                                                                                                                                                             | No |
| b.  | <p>Is there a common buildings insurance policy?</p> <p><u>If you have answered yes</u>, is the cost of the insurance included in monthly/annual factor's charges?</p>                                                                                                                                                                                                                                                                                                                                                                                                                 | No |
| c.  | Please give details of any other charges you have to pay on a regular basis for the upkeep of common areas or repair works, for example to a residents' association, or maintenance or stair fund.                                                                                                                                                                                                                                                                                                                                                                                     |    |
| 13. | Specialist work                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |    |
| a.  | <p>As far as you are aware, has treatment of dry rot, wet rot, damp or any other specialist work ever been carried out to your property?</p> <p><u>If you have answered yes</u>, please say what the repairs were for, whether you carried out the repairs (and when) or if they were done before you bought the property.</p>                                                                                                                                                                                                                                                         | No |
| b.  | <p>As far as you are aware, has any preventative work for dry rot, wet rot, or damp ever been carried out to your property?</p> <p><u>If you have answered yes</u>, please give details:</p>                                                                                                                                                                                                                                                                                                                                                                                           | No |
| c.  | <p><u>If you have answered yes</u> to 13(a) or (b), do you have any guarantees relating to this work?</p> <p><u>If you have answered yes</u>, these guarantees will be needed by the purchaser and should be given to your solicitor as soon as possible for checking. If you do not have them yourself <u>please write below who has these documents</u> and your solicitor or estate agent will arrange for them to be obtained. You will also need to provide a description of the work carried out. This may be shown in the original estimate.</p> <p>Guarantees are held by:</p> |    |
| 14. | Guarantees                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |    |
| a.  | Are there any guarantees or warranties for any of the following?                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |    |
|     | (i) Electrical work                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | No |
|     | (ii) Roofing                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           | No |
|     | (iii) Central heating                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  | No |
|     | (iv) National House Building Council (NHBC)                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | No |

# property questionnaire

|     |                                                                                                                                                                                                                             |            |
|-----|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|
|     | (v) Damp course                                                                                                                                                                                                             | No         |
|     | (vi) Any other work installations? (for example, cavity wall installation, underpinning, indemnity policy)                                                                                                                  | Don't know |
| b.  | <u>If you have answered 'yes' or 'with title deeds'</u> , please give details of the work or installations to which the guarantee(s) relate(s):                                                                             |            |
| c.  | Are there any outstanding claims under any of the guarantees listed above? <u>If you have answered yes</u> , please give details:                                                                                           | No         |
| 15. | Boundaries                                                                                                                                                                                                                  |            |
|     | So far as you are aware, has any boundary of your property been moved in the last 10 years?<br><br><u>If you have answered yes</u> , please give details:                                                                   | No         |
| 16. | Notices that affect your property                                                                                                                                                                                           |            |
|     | In the past three years have you ever received a notice:                                                                                                                                                                    |            |
| a.  | advising that the owner of a neighbouring property has made a planning application?                                                                                                                                         | Yes        |
| b.  | that affects your property in some other way?                                                                                                                                                                               | No         |
| c.  | that requires you to do any maintenance, repairs or improvements to your property?                                                                                                                                          | No         |
|     | <u>If you have answered yes to any of a–c above</u> , please give the notices to your solicitor or estate agent, including any notices which arrive at any time before the date of entry of the purchaser of your property. |            |

**Declaration by the seller(s)/or other authorised body or person(s)**

**I/We confirm that the information in this form is true and correct to the best of my/our knowledge and belief**

**Name(s): Paul Treherne**

**Date: 13/11/2024**



Home Report  
Valuation Report  
Executory Valuation  
Tax Valuations  
Separation Valuation  
Private Sale Valuation  
New Build & Plot Valuation  
Insurance Reinstatement Valuation  
Portfolio Valuation  
Rental Valuation  
Drive By & Desktop Valuation  
Energy Performance Certificate (EPC)  
Level Two Survey & Valuation Report  
Level Two Condition Report  
Expert Witness Report



Commercial Valuation  
Commercial Agency  
Acquisitions Consultancy  
Commercial Lease Advisory  
Rent Reviews  
Asset Management  
Development Appraisals & Consultancy  
Auctions  
Property Management  
Professional Services  
Licensed Trade & Leisure  
Expert Witness Report  
Rating  
Property Investment  
Public Sector



Quantity Surveying  
Building Surveying  
Project Management  
Dispute Resolution Support Services  
Principal Designer  
Clerk of Works  
Commercial EPC  
Health & Safety Management  
Employer's Agent  
Energy Consultancy  
Housing Partnerships  
Housing Consultancy  
Development Monitoring  
Mediation Services

#### Aberdeen

△△△ 01224 202800

#### Ayr

△△ 01292 267987

#### Bearsden

△△ 0141 611 1500

#### Belfast

△ 02890 912975

#### Birmingham

△ 0121 270 2266

#### Coatbridge

△△ 01236 436561

#### Cumbernauld

△△ 01236 780000

#### Dalkeith

△△ 0131 663 2780

#### Dumbarton

△△ 01389 731682

#### Dumfries

△△△ 01387 264333

#### Dundee

△△ 01382 200454  
△ 01382 220699

#### Dunfermline

△△ 01383 722337  
△ 01383 731841

#### East Kilbride

△△ 01355 248535

#### Edinburgh

△△ 0131 2251234  
△ 0131 557 9300

#### Elgin

△△ 01343 553939

#### Falkirk

△△ 01324 635 999

#### Fraserburgh

△△ 01346 517456

#### Galashiels

△△ 01896 750150

#### Glasgow

△△△ 0141 331 2807

#### Glasgow South

△△ 0141 649 8020

#### Glasgow West End

△△ 0141 353 2080

#### Greenock

△△ 01475 730717

#### Hamilton

△△ 01698 897548

#### Inverness

△△△ 01463 712239

#### Kilmarnock

△△ 01563 520318

#### Kirkcaldy

△△ 01592 205442

#### Leeds

△ 0113 322 5069

#### Livingston

△△ 01506 416777

#### London

△△ 02033 761 236

#### Montrose

△△ 01674 676768

#### Motherwell

△△ 01698 252229

#### Musselburgh

△△ 0131 653 3456

#### Oban

△△ 01631 707 800

#### Paisley

△△ 0141 889 8334

#### Perth

△△ 01738 638188  
△ 01738 631631

#### Peterhead

△△ 01779 470766

#### St Andrews

△△ 01334 477773  
△ 01334 476469

#### Saltcoats

△△ 01294 464228

#### Stirling

△△ 01786 450438  
△ 01786 474476