

Energy performance certificate (EPC)

46, High Beech Road
LOUGHTON
IG10 4BL

Energy rating

E

Valid until 7 February 2022

Certificate number

8382-6422-9310-7503-0902

Property type

Detached house

Total floor area

89 square metres

Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read [guidance for landlords on regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy efficiency rating for this property

This property's current energy rating is E. It has the potential to be D.

[See how to improve this property's energy performance.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C		
55-68	D		61 D
39-54	E	49 E	
21-38	F		
1-20	G		

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher this number, the lower your carbon dioxide (CO₂) emissions are likely to be.

The average energy rating and score for a property in England and Wales are D (60).

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says 'assumed', it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Very poor

all	Cavity wall, as built, insulated (assumed)	Good
of	Pitched, 250 mm loft insulation	Good
of	Pitched, insulated (assumed)	Good
ndow	Fully double glazed	Good
ain heating	Boiler and radiators, mains gas	Good
ain heating control	Programmer and room thermostat	Average
ot water	From main system	Good
ighting	Low energy lighting in 48% of fixed outlets	Good
oor	Suspended, no insulation (assumed)	N/A
oor	Solid, insulated (assumed)	N/A
ondary heating	Portable electric heaters (assumed)	N/A

Primary energy use

The primary energy use for this property per year is 322 kilowatt hours per square metre (kWh/m²).

[What is primary energy use?](#)

Environmental impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO₂). The energy used for heating, lighting and power in homes produces over a quarter of the UK's CO₂ emissions.

For an average household	6 tonnes of CO₂
produces	

This property produces	5.4 tonnes of CO₂
-------------------------------	-------------------------------------

This property's potential reduction	4.3 tonnes of CO₂
--	-------------------------------------

By making the [recommended changes](#), you could reduce this property's CO₂ emissions by 1.1 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

How to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from E (49) to D (61).

[What is an energy rating?](#)



Recommendation 1: Low energy lighting

Low energy lighting

Typical installation cost £28

Typical yearly saving £21

Potential rating after carrying out recommendation 1 50 | E

Recommendation 2: Heating controls (thermostatic radiator valves)

Heating controls (TRVs)

Typical installation cost £350 - £450

Typical yearly saving £37

Potential rating after carrying out recommendations 1 and 2 52 | E

Recommendation 3: Replace boiler with new condensing boiler

Condensing boiler

Typical installation cost £1,500 - £3,500

Typical yearly saving £206

Potential rating after carrying out recommendations 1 to 3 61 | D

Recommendation 4: Solar water heating

Solar water heating

Typical installation cost £4,000 - £6,000

Typical yearly saving £24

Potential rating after carrying out recommendations 1 to 4

62 | D

Recommendation 5: Internal or external wall insulation

Internal or external wall insulation

Typical installation cost £5,500 - £14,500

Typical yearly saving £228

Potential rating after carrying out recommendations 1 to 5

72 | C

Recommendation 6: Solar photovoltaic panels, 2.5 kWp

Solar photovoltaic panels

Typical installation cost £11,000 - £20,000

Typical yearly saving £219

Potential rating after carrying out recommendations 1 to 6

82 | B

Looking for energy improvements

[Find energy grants and ways to save energy in your home. \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency)

Estimated energy use and potential savings

Estimated yearly energy cost for this property

£1130

Potential saving

£264

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice \(https://www.simpleenergyadvice.org.uk/\)](https://www.simpleenergyadvice.org.uk/).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Space heating

15869.0 kWh per year

Water heating

2181.0 kWh per year

Potential energy savings by installing insulation

The assessor did not find any opportunities to save energy by installing insulation in this property.

You might be able to receive [Renewable Heat Incentive payments \(https://www.gov.uk/domestic-renewable-heat-incentive\)](https://www.gov.uk/domestic-renewable-heat-incentive). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name

Kenneth Tomlin

Telephone

01908 442105

Accreditation scheme contact details

Accreditation scheme	NHER
Assessor ID	NHER002350
Telephone	01455 883 250

Assessment details

Assessor's declaration	No related party
Date of assessment	7 February 2012
Date of certificate	8 February 2012

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk, or call our helpdesk on 020 3829 0748.

There are no related certificates for this property.